

# CERTIFICATE OF CONFORMITY

## Lead Adhesion Test Report

**SCOPE:** Covers all lead profiles.

**DURATION:** This certificate is valid from October 1<sup>st</sup> 2009 through to September 30<sup>th</sup> 2010.

**METHOD OF TESTING:** DURALEAD under the operating process outlined in I.S.O. 9000:2000 procedures, confirm that those products listed in the scope are tested to the EN1279 standards and exceed the requirements listed below. Adhesive tested in accordance with Appendix 2 of BS5713, Transition Scheme Document Issue 3.

**PEEL TEST:** Max 25mm adhesion loss after 30 minutes.

**SHEAR TEST:** Max 5mm displacement after 2 hours.

Derek Turner

**Issued: 01/10/2009**

Quality Assurance Manager